



555 Liberty Street SE / Room 305 • Salem OR 97301-3503 • Phone 503-588-6213 • Fax 503-588-6025
www.cityofsalem.net/planning • www.cityofsalem.net

May 6, 2024

LAND USE APPLICATION - COMPLETENESS REVIEW

Project Information

| | |
|-----------------------------------|--|
| Subject Property: | 4450 Commercial Street SE Suite 130 |
| Reference Number: | 24-105129-PLN |
| Application Type: | Class 1 Site Plan Review |
| Date Application Accepted: | February 28, 2024 |
| Applicant: | Jonathan Soedhijanto jsoedhijanto@rgla.com |
| Contact: | Same as Applicant |

Staff Contact

| | |
|--------------------------|--|
| Land Use Planner: | Abigail Pedersen, Planner I apedersen@cityofsalem.net / 503-540-2309 |
|--------------------------|--|

Land Use Review Comments

Prior to deeming your applications complete, modifications and/or additional information must be provided to address items detailed below.

Applicant should provide a response in the last column for each item or indicate if the item is not being provided. Items not addressed or provided may result in conditions of approval or denial of the land use application.

Your application, which is incomplete, will be deemed complete upon receipt of one of the following:

- (1) All of the missing information.
- (2) Some of the missing information and written notice from you (the applicant) that no other information will be provided.
- (3) Written notice from you (the applicant) that none of the missing information will be provided.

You have 180 days (August, 26, 2024) from the date the application was first submitted (February, 26, 2024) to respond in one of the three ways listed above, or the application will be deemed void.

The Salem Revised Code may be accessed online at the following location:

<https://www.cityofsalem.net/Pages/salem-revised-code.aspx>

Advisory Comments

Items of Concern - The following items are not listed in the SRC as specific requirements for a complete application; however, are advisories that address areas of concern on the application. **Failure to address advisory comments could result in condition of approval or denial of the application(s).**

Bike Parking
[SRC 806.055](#).

The proposed change of use triggers that the development site (Marion County Tax Lots 083W10DA/ 1300 / 1302 / 1302) be brought to conformance with requirements for bike parking. Marion County Assessor webpage lists the floor area for the development site as being 83,776. A shopping center is required to have one bike parking space for each 5,000 square feet in a shopping center. It appears that the development site has 11 existing bike parking spaces (seven in front of Trader Joe's and four in front of Rite Aid). A total of 17 bike parking spaces are required ($83,776/5,000= 16.7$) which means six more bike parking spaces are required ($17-11=6$).

All new bike parking spaces are required to meet spacing, location and surfacing requirement per [SRC 806.060](#).

Acknowledged. Landlord will install 3 bike racks between Ulta and Petco, and 3 between Petco and Rite Aid. Please see uploaded document for location.