

Laurel Christian

From: Ken Spencer <Kenneth.Spencer@pgn.com>
Sent: Wednesday, August 14, 2024 12:06 PM
To: Laurel Christian
Subject: FW: Notice of Filing / Request for Comments - Case No. DAP24-01 for 2755 Pence Lp SE
Attachments: DAP24-01 NOF-RFC.pdf

Hello,

Please add the following to your list of comments.

PGE has energized 13 kV power circuiting and 240V street light circuiting routing through the proposed work area. Our circuiting should be located prior to any excavation. Additionally, if excavation work necessitates our de-energizing the circuiting, significant coordination (and time) will be required.

Thanks.

Ken Spencer, PE Customer Operations Engineer | 503.970.7200

From: Jennifer Biberston <jbiberston@cityofsalem.net>
Sent: Wednesday, August 14, 2024 10:36 AM
To: Jennifer Biberston <jbiberston@cityofsalem.net>
Cc: Laurel Christian <LChristian@cityofsalem.net>
Subject: Notice of Filing / Request for Comments - Case No. DAP24-01 for 2755 Pence Lp SE

This email is from someone outside PGE.

Please take care when opening links, attachments or responding to this email.

Hello,

The Notice of Filing/ Request for Comments for Class 2 Driveway Approach Permit Case No. DAP24-01 for 2755 Pence Lp SE is attached for your information. Comments are due **August 28, 2024, by 5:00 p.m.** Hard copies go out in the mail today for those of you who are to receive one.

Application Summary: Proposed driveway approach to serve an existing building.

Please direct questions or comments to the **CASE MANAGER:**

Laurel Christian

Lchristian@cityofsalem.net

503-584-4632

Thank you,

Jennifer Biberston

Administrative Analyst I

City of Salem | Community Planning and Development | Planning

555 Liberty St SE, Room 305, Salem OR 97301

Jbiberston@cityofsalem.net | 503-540-2315

