



555 Liberty Street SE / Room 305 • Salem OR 97301-3503 • Phone 503-588-6213 • Fax 503-588-6025  
www.cityofsalem.net/planning • www.cityofsalem.net

August 27, 2024

## LAND USE APPLICATION – COMPLETENESS REVIEW

### Project Information

<b>Subject Property:</b>	3200 Pheasant Ave SE
<b>Reference Number:</b>	24-116270-PLN & 24-117854-PLN
<b>Application Type:</b>	Partition and Tree Conservation Plan
<b>Date Application Accepted:</b>	August 1, 2024
<b>Applicant:</b>	Barker Surveying carol@barkerwilson.com
<b>Contact:</b>	Montgomery Construction Group Corporation (Chad Montgomery) <a href="mailto:chad@mcgcorp.net">chad@mcgcorp.net</a>  Keith Kohler (Barker Surveying) <a href="mailto:keith@barkerwilson.com">keith@barkerwilson.com</a>

### Staff Contact

<b>Land Use Planner:</b>	Jacob Brown, Planner II <a href="mailto:JRBrown@cityofsalem.net">JRBrown@cityofsalem.net</a> / 503-540-2347
<b>Infrastructure Planner:</b>	Laurel Christian, Infrastructure Planner III <a href="mailto:lchristian@cityofsalem.net">lchristian@cityofsalem.net</a> / 503-584-4632

### Land Use Review Comments

**Prior to deeming your applications complete, modifications and/or additional information must be provided to address items detailed below.**

**Applicant should provide a response in the last column for each item or indicate if the item is not being provided. Items not addressed or provided may result in conditions of approval or denial of the land use application.**

Your application, which is incomplete, will be deemed complete upon receipt of one of the following:

- (1) All of the missing information.
- (2) Some of the missing information and written notice from you (the applicant) that no other information will be provided.
- (3) Written notice from you (the applicant) that none of the missing information will be provided.

**You have 180 days (January 28, 2025) from the date the application was first submitted (August 1, 2024) to respond in one of the three ways listed above, or the application will be deemed void.**

The Salem Revised Code may be accessed online at the following location:

<https://www.cityofsalem.net/Pages/salem-revised-code.aspx>

### **Completeness Review Items**

**Submittal Requirements** – The following items have been identified as required material to be provided by the application(s) prior to deeming the application “complete”:

<b>Submittal Requirement</b>	<b>Description</b>	<b>Applicant Response</b> <i>ie. Written Response, Submitted, Not Providing</i>
<b>Tree Conservation Plan SRC 808.035</b>	<p>As required under Salem Revised Code (SRC) <a href="#">808.035</a>, a tree conservation plan is required in conjunction with any development proposal for the creation of lots or parcels to be used for single, two, three, and four family uses. The subject property is located within the RS-Single Family Residential zone district which primarily permits the listed uses.</p> <p>A tree inventory and tree conservation plan are required to be submitted and must meet the requirements as stated under SRC 808.035. The Tree Conservation Plan application must be submitted separately from the partition application through the PAC portal as they cannot be consolidated. The Tree Conservation Plan decision will be issued following the completion of the appeal period for the partition. Upon request, Staff can create the Tree Conservation application, or the applicant can submit separately.</p> <p><b>A Tree Conservation Plan Application has been setup under 24-117854-PLN. The listed fee of \$747 for the application will need to be paid.</b></p>	
<b>Partition Plan</b>	Please provide a partition plan with no preliminary outline for future development. At this time, the proposed future development is not be reviewed.	
<b>Stormwater Management</b>  <b>Not Addressed. Per SRC 71.080 storm facilities are required to serve divided property.</b>	The application does not provide sufficient details to identify how the site is compliant with SRC 71, specifically the requirements for Green Stormwater Infrastructure (GSI) pursuant to PWDS Appendix 4E. A description of the proposed stormwater management system shall be provided pursuant to SRC 205.030(e). The description should include the proposed location of GSI facilities for onsite stormwater treatment and the plan for offsite disposal in accordance with the Public Works Design Standards.	

### **Advisory Comments**

**Items of Concern** - The following items are not listed in the SRC as specific requirements for a complete application; however, are advisories that address areas of concern on the application. **Failure to address advisory comments could result in condition of approval or denial of the application(s).**

Item	Description	Applicant Response <i>ie. Written Response, Submitted, Not Providing</i>
<b>Chapter 808 – Preservation of Trees and Vegetation</b>		
<b>Tree Conservation Plan</b>	<p>Per the preliminary plan, the two existing trees on the property are located within/near the footprint of a proposed building. Please note that the approval criteria of SRC <a href="#">808.035</a> (d) if less than 30 percent of the trees are designated for preservation that applicant shall demonstrate that there “are no reasonable design alternatives that would enable preservation of such trees” and that mitigation measures required under SRC 808.035(e) shall be met. Please identify conformance with the approval criteria within a written statement and additional documentation as necessary.</p> <p>As all trees will be removed on the property, please amend the written statement to address SRC 808.035(e) which requires that mitigation measures be proposed when less than 30 percent of the trees are being preserved. These mitigation measures will be conditioned as part of the tree conservation plan decision.</p>	
<b>Chapter 511– Single Family Residential</b>		
<b>SRC 511.010 Lot Standards</b>	<p>Per SRC 511.010 (b) Table 511-2, the proposed lot depth of 145 feet exceeds the maximum allowed for a lot within the RS zone. The maximum is 300% of the average lot width (proposed 40 feet). This would set the maximum allowed lot depth to 120 feet. Per SRC <a href="#">250.005</a> (a), a Class 2 Adjustment is required when a standard is being increased by more than 20 percent (21%). Within a written statement the applicant will need to address the approval criteria of SRC 250.005 (d)(2).</p>	