



Oregon

Tina Kotek, Governor



Aug. 29, 2024

Tyler Roth, AKS Engineering & Forestry, LLC
3700 River Rd, Suite 1
Keizer, OR 97303
rotht@aks-eng.com

3040 25th Street, SE
Salem, OR 97302-1125
Phone: (503) 378-4880
Toll Free: (800) 874-0102
FAX: (503) 373-1688

Subject: Determination Letter Regarding the Construction or Alteration of a Building at 51 Feet in Height Located in Salem, Oregon

ODAV Aviation Reference Number: 2024-ODAV-241-OE
Proponent/Representative Identifier: SW corner of State St and Kettle Ct
FAA Aeronautical Study Number(s) (ASN), if Provided: 2024-ANM-2662-OE¹

The Oregon Department of Aviation (ODAV) has conducted an aeronautical study of this proposed construction and has determined that notice to the FAA is required. The structure exceeds FAR Part 77.9 (a, b, or c) and/or Obstruction Standards of OAR 738-070-0100.

This determination is based, in part, on the foregoing description which includes specific coordinates and heights. Any changes to the original application will void this determination. Any future construction or alteration to the original application will require a separate notice to ODAV.

Unless extended, revised, or terminated, this determination will expire 18 months after its effective date, regardless of whether the proposed construction or alteration has been started, or on the date the proposed construction or alteration is abandoned, whichever is earlier.

Findings & Mitigation:

- ☒ We do not object with conditions to the construction described in this proposal. This determination does not constitute ODAV approval or disapproval of the physical development involved in the proposal. It is a determination with respect to the safe and efficient use of navigable airspace by aircraft and with respect to the safety of persons and property on the ground.
- ☐ Marking and lighting are required for aviation safety. It shall be installed and maintained in accordance with FAA Advisory Circular 70/7460-1M.
- ☐ The proposed structure should be lowered to a height that is no longer an obstruction to the imaginary surfaces set forth in FAA FAR 77.
- ☐ The proposed obstruction should be relocated outside the airport primary and horizontal surface FAA FAR 77.

Sincerely,

Brandon Pike, Aviation Planner

¹ Any FAA ASN listed in this letter is provided by the proponent and/or their representative, and may not be accurate. It is included only for cross-referencing purposes.