



WESTECH ENGINEERING, INC.
CONSULTING ENGINEERS & PLANNERS

July 13, 2012

Pamela Cole
City of Salem
Community Development
555 Liberty Drive SE Rm 305
Salem, OR 97301-3503

RE: Urban Growth Area Development Permit (UGA) & Type II Site Plan Review for the
2500 Block of Boone Road – Trash Enclosure Details
JO# 2672.0000.0

Dear Pamela:

This letter is intended to summarize our trash enclosure details that are not illustrated on the site plan review site plan. They include the following:

- Waste hauler for this area - Allied Waste (contacted Dana Eastman via telephone)
- Date contacted - July 12, 2012
- Trash coverage requirements – just covered trash cans, no structure required (also confirmed per my conversation with Jim Gengler at Environmental Services)
- Overhead clearance – NA per above.
- Receptacle sizes used based on like uses and per Allied Waste – (2), 4 CY cans (6.5 ft x 4.5ft x 4.5 ft.), (2), 2 CY recycle bins (6.5ft x 3.5ft x 3.5 ft), 2, 90 gallon co-mingle trash cans.

I hope this information addresses your questions regarding solid waste and recycles storage for this project. If you have any questions or need additional information regarding this matter, please contact us at (503) 585-2474.

Sincerely,

WESTECH ENGINEERING, INC.


W. Josh Wells, P.E.

wjw

cc: PacTrust, Scott Hodson & Matt Oyen