

From: [Jennifer Scott](#)
To: [Bryce Bishop](#); [Steve Ward](#)
Cc: [Glenn Davis](#)
Subject: RE: Strong Heights Landscape Strip
Date: Tuesday, May 11, 2021 9:06:37 AM

Bryce and Steve,

4 feet is the minimum needed in order to install street trees for the City of Salem. Wider is better, of course, but my understanding is that 4 feet is acceptable.

Thanks,

Jennifer Scott

Program Manager

City of Salem | Public Works Department

555 Liberty Street SE, Suite 325, Salem Oregon 97301-3513

jrscott@cityofsalem.net

Office: 503-588-6211 ext. 7349 | Cell: [503-871-2823](tel:503-871-2823)

[Facebook](#) | [Twitter](#) | [YouTube](#) | CityofSalem.net



From: Bryce Bishop <BBishop@cityofsalem.net>
Sent: Tuesday, May 11, 2021 7:06 AM
To: Jennifer Scott <JRScott@cityofsalem.net>
Subject: FW: Strong Heights Landscape Strip

Jennifer,

FYI. Thanks!

From: Steve Ward <sward@westech-eng.com>
Sent: Tuesday, May 11, 2021 7:03 AM
To: Glenn Davis <GDAVIS@cityofsalem.net>
Cc: Bryce Bishop <BBishop@cityofsalem.net>
Subject: Strong Heights Landscape Strip

Glenn,

Please see the attached. Bryce is asking me to confirm the 4' planted for the private streets is acceptable to PW. Can you please respond to this email ASAP. I assume it is acceptable since to only comment PW made on the application is you concern with the development meeting the WQ Standards. WE are working to insure we meet the WQ Requirements.

Steven A. Ward PE
Westech Engineering Inc.
3841 Fairview Industrial Drive SE
Suite 100
Salem, OR 97302
Office 503-585-2474
Mobile 503-931-3460