


CHAPTER 810.-LANDSLIDE HAZERDS

TABLE 810-1A. EARTHQUAKE-INDUCED LANDSLIDE SUSCEPTIBILITY RATINGS

Property identified under very low or low categories on IMS-18.

ASSIGNED POINT VALUE = 0

IMS-18



EXPLANATION

Hazard ratings




TABLE 810-1B. WATER-INDUCED LANDSLIDE SUSCEPTIBILITY RATINGS

IMS-5

ASSIGNED POINT VALUE = 0



TABLE 810-1C. ACTIVITY SUSCEPTIBILITY RATINGS

Installation or construction of any structure greater than 500 square feet in area-

Commercial or industrial building permit

ASSIGNED POINT VALUE = 3

TABLE 810-1D. CUMULATIVE SCORE

Total Points = 3

TABLE 810-1E. TOTAL LANDSLIDE HAZARD RISK

4 or fewer points-Category A – Low-No Requirement