

Inspection Report

Presented To

DAS ENTERPRISE ASSET MGNT

For

EXECUTIVE BLDG

155 Cottage St
SALEM, Oregon 97301
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Monday, April 04, 2022

Test Session :04 Apr 2022 A FH LK7109

Test Plans : Fire Hydrant - Annual

ACCEPTED BY

Laura Bindley
DAS ENTERPRISE ASSET MGNT
1225 FERRY ST SE U100
SALEM, Oregon 97301-4278
United States

TESTED BY

Richard Hooper
Western States Fire Protection
Portland
17500 S.W. 65th Ave
Lake Oswego, OR 97035
United States



Inspection Summary

Building Information

PROPERTY	EXECUTIVE BLDG	CONTACT	Laura Bindley
ADDRESS	155 Cottage St	PHONE	
CITY/STATE/ZIP	SALEM, Oregon 97301	MOBILE	+1 503-932-9096
COUNTRY	United States	EMAIL	laura.bindley@oregon.gov

Inspector Information

COMPANY	Western States Fire Protection Portland	CONTACT	Richard Hooper
ADDRESS	17500 S.W. 65th Ave Lake Oswego, OR 97035	LICENSE NUMBER	
		PHONE	+1 503-657-5155
COUNTRY	United States	EMAIL	rich.hooper@wsfp.us

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Water-Based Fire Protection Equipment	2	2(100%)	2(100%)	0(0%)

General Information

Test Session Comment: Fire Hydrant's were full flowed using a Mini Hose Monster Kit.

Corner of Cottage Street & Court Street

Static~ 85 PSI
Residual~ 80 PSI
Pitot~ 30
GPM~ 854
Max flow available GPM~ 3412

Corner of Church Street & State Street by Parking Garage

Static~ 95 PSI
Residual~ 85 PSI
Pitot~ 28
GPM~ 825
Max flow available GPM~ 2449

Certification

The equipment specified herein was inspected and tested, with the inspection completed on Monday, April 04, 2022

ACCEPTED BY 04/04/2022
Laura Bindley
Building Representative

TESTED BY 04/04/2022
Richard Hooper
Technician



Testing Details

Water-Based Fire Protection Equipment

Passed				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Hydrant	FH	Corner of Church Street & State Street by Parking Garage	Manual	4/4/2022 3:50:05 PM
	Comment:	Fire Hydrant's were full flowed using a Mini Hose Monster Kit.		
		Corner of Church Street & State Street by Parking Garage		
		Static~ 95 PSI Residual~ 85 PSI Pitot~ 28 GPM~ 825 Max flow available GPM~ 2449		
Hydrant threads	Passed	Manufacturer	Kennedy	
Hydrant drain	Passed	Model	5 1/4 X 2 1/2 X 2 1/2	
Hydrant access	Passed	Visual Inspection	Passed	
Hydrant Set	Passed	Functional Inspection	Passed	
Hydrant	FH	Corner of Cottage Street & Court Street	Manual	4/4/2022 3:46:04 PM
	Comment:	Fire Hydrant's were full flowed using a Mini Hose Monster Kit.		
		Corner of Cottage Street & Court Street		
		Static~ 85 PSI Residual~ 80 PSI Pitot~ 30 GPM~ 854 Max flow available GPM~ 3412		
Hydrant threads	Passed	Manufacturer	Clow	
Hydrant drain	Passed	Model	5 1/4 X 2 1/2 X 2 1/2	
Hydrant access	Passed	Visual Inspection	Passed	
Hydrant Set	Passed	Functional Inspection	Passed	