

**Building and Safety**

PAC: (503) 588-6256  
Inspections: (503) 588-6256  
Fax: (503) 588-6115

**City Hall**

555 Liberty St SE  
Room 320  
Salem, OR 97301-3503

SALEM FIRE ALARM  
PO BOX 12789  
SALEM OR 97309-0789

**Electrical Seq #: 21-102472-E**  
**Date Issued: Jan 28, 2021**

**Job Site Address:** 465 DIVISION ST NE **Project Name:** 465 DIVISION STREET NE

**Description of Work:** Commercial - Limited Energy - 64900-BEL-21-00101 117262 1/27/2021 9:26 am;  
BUILDING IS A 3 STORY, FULLY SPRINKLED, GROUPS A-3 AND B; OCCUPANCY  
WITH A-3 BEING THE MOST RESTRICTIVE, AT LEAST A 100 OCCUPANTS ABOVE  
THE LEVEL OF DISCHARGE. PER CURRENT OSSC MINIMUM SYSTEM  
REQUIREMENT IS SPRINKLER MONITORING WITH OCCUPANT NOTIFICATION  
THROUGHOUT. THIS IS THE BASIS OF THE SYSTEM DESIGN. ADDITIONALLY  
ELEVATOR RECALL IS INCORPORATED INTO THE SYSTEM. CERTAIN ROOMS  
WILL HAVE PRE-ACTION SPRINKLER CONTROLLED BY A; SEPARATE PANEL  
THAT IS MONITORED BY THE MAIN PANEL; NEW THREE STORY OFFICE  
BUILDING WITH CREDIT UNION AND COVERED PARKING ON FIRST LEVEL; B  
OCCUPANCY

**Owner:**  
MAPS CREDIT UNION  
451 DIVISION ST NE  
SALEM OR 97301

**Contractor:**  
SALEM FIRE ALARM  
PO BOX 12789  
SALEM OR 97309-0789  
WORK: (503) 364-4566

**Info:**

In City Limits?: Yes  
Electrical Contractor's License #: 24133CLE  
Historic Zone: No

Contractors' Construction Board #: 76884  
Plan Type Review: NONE

1st Review Estimated Turn Time: OVER THE  
COUNTER  
Historic Building: No

**Fixtures:**

1 Limited Energy - Commercial

**This permit expires if work or construction authorized is not commenced with 180 days, or if construction or work is suspended or abandoned for a period of 180 days at any time after work has commenced. Issued permits are not eligible for a refund if work has not had any activity or extension request within 180 days.**