

Building and Safety

PAC: (503) 588-6256
Inspections: (503) 588-6256
Fax: (503) 588-6115

**City Hall**

555 Liberty St SE
Room 320
Salem, OR 97301-3503

SALEM FIRE ALARM
PO BOX 12789
SALEM OR 97309-0789

Fire Seq #: 22-110628-FI
Date Issued: Jun 29, 2022

Property Address: 4000 DEERHAVEN DR NE **Project Name:** 4000 DEERHAVEN DRIVE NE
Legal Description: Blk: 0
Tax Lot#: 073W12AC03201 Twn: 7 Rng: 3 Sec: 12
Description of Work: Commercial - Fire Alarm - Alteration - PROJECT IS A TWO STORY ELEMENTARY SCHOOL WITH SITE DEVELOPMENT. NEW 1ST FLOOR CLASSROOM 106A, AND NEW 2ND FLOOR CLASSROOM 206A WILL HAVE NEW SERIES SMOKE DETECTION INSTALLED DUE TO THE AGE THE EXISTING FIRE ALARM CONTROL PANEL NEW PARTS DO NOT EXIST AND NEW SIEMENS NOTIFICATION DEVICE TIED INTO THE NEAREST CIRCUIT. FIRE ALARM SYSTEM IS AN EXISTING SIEMENS MXL FIRE ALARM CONTROL PANEL WITH TEMPORAL 3 EVACUATION NOTIFICATION THAT WILL BE MIGRATED WITH THE A NEW SIEMENS FC922 COMPACT FIRE ALARM CONTROL PANEL. EXISTING DEVICES WILL BE MIGRATED TO THE SIEMENS COMPACT PANEL WITH THE FCL2004-U1 MXL DEVICE INTERFACE MODULE.

Info:

Contractors' Construction Board #: 76884
Historic and Cultural Resource Protection
Zone: Yes

Valuation: \$33,280.00

County Property Class: C10

Owner:

SALEM KEIZER SCHOOL DISTRICT 24J
PO BOX 12024
SALEM OR 97309
Work: (503) 391-1133

Contractor:

SALEM FIRE ALARM
PO BOX 12789
SALEM OR 97309-0789
WORK: (503) 364-4566

Contact:

JILL CHASE
PO BOX 12789
SALEM OR 97309-0789
Work: (509) 773-3291

Applicant:

SALEM FIRE ALARM
PO BOX 12789
SALEM OR 97309-0789
Work: (503) 364-4566

This permit expires if work or construction authorized is not commenced with 180 days, or if construction or work is suspended or abandoned for a period of 180 days at any time after work has commenced. Issued permits are not eligible for a refund if work has not had any activity or extension request within 180 days.