

**Building and Safety**

PAC: (503) 588-6256  
Inspections: (503) 588-6256  
Fax: (503) 588-6115

**City Hall**

555 Liberty St SE  
Room 320  
Salem, OR 97301-3503

JILL CHASE  
PO BOX 12789  
SALEM OR 97309-0789

**Electrical Seq #:** 23-123455-E  
**Date Issued:** Dec 04, 2023

**Job Site Address:** 4646 PORTLAND RD NE **Project Name:** 4646 PORTLAND ROAD NE

**Description of Work:** Commercial - Limited Energy - PROJECT WILL INCLUDE THE FOLLOWING: BLDG B;  
47 NEW SK SLF SOUNDERS, 5 NEW SK SLF SOUNDER STROBES, AND 5; STROBE  
ONLY'S FOR RESIDENT ROOMS; NEW SK MONITOR MODULES FOR NEW  
SPRINKLER RISERS AND TO; MONITOR POWER SUPPLIES; 2 NEW RELAY  
MODULES FOR POWER SUPPLY TRIP; 2 NEW POWER SUPPLY; TIE NEW DEVICES  
INTO EXISTING SK 6700 FACP; PROJECT DOESN'T INCLUDE ANY MODIFICATION  
ON EXISTING INITIATING; OR NOTIFICATION DEVICES. EXISTING FIRE ALARM  
SYSTEM WILL REMAIN; IN SERVICE.

**Owner:****Contractor:**

SALEM FIRE ALARM  
PO BOX 12789  
SALEM OR 97309-0789  
WORK: (503) 364-4566

**Info:**

In City Limits?: Yes  
Electrical Contractor's License #: 24-133CLE  
Historic Zone: No

Contractors' Construction Board #: 76884  
Supervising Electrician #: 5766S

Electrical Review Reason: Not Required  
Historic Building: No

**Fixtures:**

1 Fire alarm installation

**This permit expires if work or construction authorized is not commenced with 180 days, or if construction or work is suspended or abandoned for a period of 180 days at any time after work has commenced. Issued permits are not eligible for a refund if work has not had any activity or extension request within 180 days.**