

Building and Safety

PAC: (503) 588-6256
Inspections: (503) 588-6256
Fax: (503) 588-6115

**City Hall**

555 Liberty St SE
Room 320
Salem, OR 97301-3503

JILL CHASE
PO BOX 12789
SALEM OR 97309-0789

Electrical Seq #: 24-101322-E
Date Issued: Jan 08, 2024

Job Site Address: 375 MADRONA AV S **Project Name:** 375 MADRONA AVENUE S

Description of Work: Commercial - Limited Energy - Occupancy type: Existing sprinkled A occupancy.; Project is an interior remodel of an existing church including office space, restrooms, balcony seating and modification of fire sprinklers. Fire alarm devices will be relocated and added to meet the current code. Project will include the following:; 1 PAD-4 Siemens Power Supply; 1 OP921 Smoke Detector; 4 SL2 Siemens Strobes; 8 SL2 Siemens Horn Strobes; Reuse existing FC901 and AES Mesh Radio; Reuse existing notification devices (EST) in the sanctuary areas.

Owner:**Contractor:**

SALEM FIRE ALARM
PO BOX 12789
SALEM OR 97309-0789
WORK: (503) 364-4566

Info:

In City Limits?: Yes
Electrical Contractor's License #: 24-133CLE
Historic Zone: No

Contractors' Construction Board #: 76884
Supervising Electrician #: 5766S

Electrical Review Reason: Occupancy A, E,
I-2, I-3
Historic Building: No

Fixtures:

1 Fire alarm installation

This permit expires if work or construction authorized is not commenced with 180 days, or if construction or work is suspended or abandoned for a period of 180 days at any time after work has commenced. Issued permits are not eligible for a refund if work has not had any activity or extension request within 180 days.