

Building and Safety

PAC: (503) 588-6256
Inspections: (503) 588-6256
Fax: (503) 588-6115

**City Hall**

555 Liberty St SE
Room 320
Salem, OR 97301-3503

JILL CHASE
PO BOX 12789
SALEM OR 97309-0789

Electrical Seq #: 24-103755-E
Date Issued: Feb 15, 2024

Job Site Address: 4646 PORTLAND RD NE **Project Name:** 4646 PORTLAND ROAD NE
Description of Work: Commercial - Limited Energy - Project will include the following: Building A: 47 new SK SLF sounders, 5 new SK SLF sounder strobes and 5; strobe only's for resident rooms; new SK monitor modules for new sprinkler risers and to: monitor power supplies; 2 new relay modules for power supply trip; 2 new power supply; tie new devices into existing SK 6700 FACP; project doesn't include any modification on existing initiating; or notification devices. Existing fire alarm system will remain in service.

Owner:
MNAH LLC
605 CENTER ST NE
SALEM OR 97301

Contractor:
SALEM FIRE ALARM
PO BOX 12789
SALEM OR 97309-0789
WORK: (503) 364-4566

Info:

In City Limits?: Yes
Electrical Contractor's License #: 24-133CLE
Historic Zone: No

Contractors' Construction Board #: 76884
Supervising Electrician #: 5766S

Electrical Review Reason: Emergency system
Historic Building: No

Fixtures:

1 Fire alarm installation

This permit expires if work or construction authorized is not commenced with 180 days, or if construction or work is suspended or abandoned for a period of 180 days at any time after work has commenced. Issued permits are not eligible for a refund if work has not had any activity or extension request within 180 days.