

**Building and Safety**

PAC: (503) 588-6256  
Inspections: (503) 588-6256  
Fax: (503) 588-6115



**City Hall**

555 Liberty St SE  
Room 320  
Salem, OR 97301-3503

SALEM FIRE ALARM  
PO BOX 12789  
SALEM OR 97309-0789

**Electrical Seq #: 24-123494-E**  
**Date Issued: Nov 20, 2024**

**Job Site Address:** 3975 COMMERCIAL ST SE **Project Name:** 3975 COMMERCIAL STREET SE

**Description of Work:** Commercial - Limited Energy - OCCUPANCY TYPE: M EXISTING SILENT KNIGHT SK5208 ALL EXISTING DEVICES WILL REMAIN IN SERVICE CONSTRUCTION INCLUDES ONE NEW SPRINKLER VAULT PROJECT WILL INCLUDE THE FOLLOWING: RUN NEW CABLE TO THE NEW SPRINKLER VAULT TO THE SPARE ZONE OF THE EXISTING FIRE ALARM PANEL. \* AHJ TO BE CONTACTED PRIOR TO ACCEPTANCE TESTING. AHJ TO BE CONTACTED PRIOR TO ACCEPTANCE TESTING. \* SITE TO BE ON FIRE WATCH DURING PANEL CUT OVER, PROPERTY OWNER MANAGER TO SITE TO BE ON FIRE WATCH DURING PANEL CUT OVER, PROPERTY OWNER MANAGER TO COORDINATE IF NECESSARY.

**Owner:**  
WYANT SOUTHGATES LLC  
3975 COMMERCIAL ST SE  
SALEM OR 97301

**Contractor:**  
SALEM FIRE ALARM  
PO BOX 12789  
SALEM OR 97309-0789  
WORK: (503) 364-4566

**Info:**  
In City Limits?: Yes Contractors' Construction Board #: 76884 Electrical Review Reason: Emergency system  
Electrical Contractor's License #: 24-133CLE Supervising Electrician #: 5766S Historic Building: No  
Historic Zone: No

**Fixtures:**  
1 Fire alarm installation

**This permit expires if work or construction authorized is not commenced with 180 days, or if construction or work is suspended or abandoned for a period of 180 days at any time after work has commenced. Issued permits are not eligible for a refund if work has not had any activity or extension request within 180 days.**