

Building and Safety

PAC: (503) 588-6256
Inspections: (503) 588-6256
Fax: (503) 588-6115



City Hall

555 Liberty St SE
Room 320
Salem, OR 97301-3503

CHRISTINE ZIEGLER
2501 SE COLUMBIA WY STE 100
VANCOUVER OR 98661

Fire Seq #: 25-103884-FI
Date Issued: Feb 26, 2025

Property Address: 3975 COMMERCIAL ST SE **Project Name:** 3975 COMMERCIAL STREET SE

Legal Description: Blk: 0
Tax Lot#: 083W03DC03303 Twn: 8 Rng: 3 Sec: 03

Description of Work: Commercial - Fire Sprinkler - Alteration - elevate 3" mains at the East and West walls to follow the slope of the deck and remain below structure; elevate the 3" main on the North wall to the deck and wrap under three glulam beams; add pendent and upright heads to conform to new wall and ceiling layout for tenant improvement

Info:

Contractors' Construction Board #: 67508 Valuation: \$31,473.00 County Property Class: 201
Historic and Cultural Resource Protection
Zone: No

Owner:

WYANT SOUTHGATES LLC
PO BOX 17008
SALEM OR 97305-7008
Work: (503) 363-5635

Contractor:

COSCO FIRE PROTECTION
2501 SE COLUMBIA WAY SUITE 100
VANCOUVER WA 98661
WORK: (360) 883-6383

Contact:

CHRISTINE ZIEGLER
2501 SE COLUMBIA WY STE 100
VANCOUVER OR 98661

Applicant:

CHRISTINE ZIEGLER
2501 SE COLUMBIA WY STE 100
VANCOUVER OR 98661

This permit expires if work or construction authorized is not commenced with 180 days, or if construction or work is suspended or abandoned for a period of 180 days at any time after work has commenced. Issued permits are not eligible for a refund if work has not had any activity or extension request within 180 days.